

РӨСӨЙ ФЕДЕРАЦИЯҢЫ
БАШКОРТОСТАН РЕСПУБЛИКАҢЫ
"САЛАВАТБЫЯЛА"
АКЦИОНЕРЗАР ЙӘМГНӘТЕ
453253, РФ, РБ
Салават к. Индустриаль ур. 18
тел.: (3476)37-72-09, секретарь 37-71-55,
коммерция хезмәте 37-71-20,
www.salstek.ru

САЛАВАТСТЕКЛО



104213/A/0001/UK/RUS

Система менеджмента
качества сертифицирована
на соответствие требованиям
ISO 9001:2015



104213/B/0001/SM/RUS

Система менеджмента
качества сертифицирована
на соответствие требованиям
IATF 16949:2016

РОССИЙСКАЯ ФЕДЕРАЦИЯ
РЕСПУБЛИКА БАШКОРТОСТАН
АКЦИОНЕРНОЕ ОБЩЕСТВО
«САЛАВАТСТЕКЛО»
453253, РФ, РБ
г. Салават, ул. Индустриальная, 18
тел.: (3476) 37-72-09, секретарь 37-71-55,
коммерческая служба 37-71-20,
www.salstek.ru

ИНН 0266004050, КПП 026601001, ОКПО 04616815, ОГРН 1020201995043, р/с 40702810806404000298, Башкирское отделение № 8598 ПАО Сбербанк, БИК 048073601, к/с № 30101810300000000601



DECLARATION OF CONFORMITY

No. 026-2021/11

Unique identification code of the product-type:	Mirror Mirroline
Intended use	Buildings and construction works
Manufacturer:	“Salavatsteklo” JSC Industrialnaya str. 18, Salavat, Republic of Bashkortostan, Russia 453253
Harmonised standart	EN 1036-2 Glass in building - Mirrors from silver-coated float glass for internal use - Part 2: Evaluation of conformity - Product standard
AVCP system:	3
Notified body:	IKATES, s.r.o. - Laboratory for glass and building products testing Testing laboratory No 1139. Test report No.: 1394-CPR-156/2020

Characteristics:	Mirroline				Mirroline Grey	Mirroline Bronze
	3 mm	4 mm	5 mm	6 mm	4 mm	4 mm
Resistance to fire	NPD	NPD	NPD	NPD	NPD	NPD
Reaction to fire	A1*	A1*	A1*	A1*	A1*	A1*
External fire performance	NPD	NPD	NPD	NPD	NPD	NPD
Bullet resistance	NPD	NPD	NPD	NPD	NPD	NPD
Explosion resistance	NPD	NPD	NPD	NPD	NPD	NPD
Burglar resistance	NPD	NPD	NPD	NPD	NPD	NPD
Pendulum body impact resistance	NPD	NPD	NPD	NPD	NPD	NPD
Resistance against sudden temperature changes and temperature differentials	40K					
Resistance against wind, snow, permanent load and/or imposed loads of the glass unit	NPD	NPD	NPD	NPD	NPD	NPD
Direct airborne sound insulation	NPD	NPD	NPD	NPD	NPD	NPD
Thermal properties	NPD	NPD	NPD	NPD	NPD	NPD
Condensation water test an constant temperature in atmosphere with	PASS	PASS	PASS	PASS	PASS	PASS
Copper accelerated acid salt spray (CASS)	PASS	PASS	PASS	PASS	PASS	PASS
Varnish adhesion	PASS	PASS	PASS	PASS	PASS	PASS
Light reflection (pV)	0,92	0,92	0,90	0,88	0,39	0,39

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Salavat, Russia
2021/11/25

Agureev S.A. General Director of
“SALAVATSTEKLO” JSC